

各樓館九大能源佔比

館別		空調系統	照明系統	冷凍冷藏系統	事務設備系統	送排風系統	給水污水系統	電梯系統	熱能用量的相當電力用量 (kWh/Y)	其他	該空間總耗能 (kWh/Y) 合計相當電力
行政大樓	能耗	164,313	97,806	11,213	149,812	-	8,161	-	-	14,461	445,766
	占比	36.86%	21.94%	2.52%	33.61%	0.00%	1.83%	0.00%	0.00%	3.24%	100.00%
驚聲大樓	能耗	887,001	209,021	14,933	278,145	-	38,920	90,000	155,984	679,586	2,353,590
	占比	37.69%	8.88%	0.63%	11.82%	0.00%	1.65%	3.82%	6.63%	28.87%	100.00%
松濤館	能耗	380,399	68,573	267,479	51,853	48,564	78,721	20,000	-	491,363	1,406,952
	占比	27.04%	4.87%	19.01%	3.69%	3.45%	5.60%	1.42%	0.00%	34.92%	100.00%
會文館	能耗	209,707	35,694	162,096	34,470	340	2,519	-	-	240,931	685,757
	占比	30.58%	5.21%	23.64%	5.03%	0.05%	0.37%	0.00%	0.00%	35.13%	100.00%
海博館	能耗	96,515	44,754	6,351	39,903	60	2,701	-	-	12,503	202,787
	占比	47.59%	22.07%	3.13%	19.68%	0.03%	1.33%	0.00%	0.00%	6.17%	100.00%
覺生綜合大樓	能耗	400,104	65,199	7,042	73,719	-	-	-	-	11,732	557,796
	占比	71.73%	11.69%	1.26%	13.22%	0.00%	0.00%	0.00%	0.00%	2.10%	100.00%
商管大樓	能耗	1,077,774	279,592	71,737	721,165	5,000	104,752	135,000	-	415,852	2,810,872
	占比	38.34%	9.95%	2.55%	25.66%	0.18%	3.73%	4.80%	0.00%	14.79%	100.00%
化學館	能耗	1,462,692	388,748	115,646	305,133	1,043,952	26,846	30,000	-	1,290,026	4,663,042
	占比	31.37%	8.34%	2.48%	6.54%	22.39%	0.58%	0.64%	0.00%	27.66%	100.00%
工學大樓	能耗	1,828,788	275,828	52,398	953,981	127,370	30,186	90,000	1,814	2,013,383	5,373,749
	占比	34.03%	5.13%	0.98%	17.75%	2.37%	0.56%	1.67%	0.03%	37.47%	100.00%
工學館	能耗	273,516	51,033	8,433	97,782	1,747	8,161	-	-	49,706	490,377
	占比	55.78%	10.41%	1.72%	19.94%	0.36%	1.66%	0.00%	0.00%	10.14%	100.00%
宮燈教室	能耗	6,651	15,679	-	4,460	-	-	-	-	10,800	37,590
	占比	17.69%	41.71%	0.00%	11.86%	0.00%	0.00%	0.00%	0.00%	28.73%	100.00%
文學館	能耗	291,123	93,572	4,039	176,482	-	4,052	-	-	130,121	699,389
	占比	41.63%	13.38%	0.58%	25.23%	0.00%	0.58%	0.00%	0.00%	18.60%	100.00%
游泳館	能耗	522,448	105,139	14,016	27,049	-	48,968	60,000	-	785,531	1,563,151
	占比	33.42%	6.73%	0.90%	1.73%	0.00%	3.13%	3.84%	0.00%	50.25%	100.00%
傳播館	能耗	260,375	77,940	2,784	75,886	198	10,804	-	-	88,469	516,456
	占比	50.42%	15.09%	0.54%	14.69%	0.04%	2.09%	0.00%	0.00%	17.13%	100.00%
科學館	能耗	652,598	197,926	20,414	595,956	4,573	2,701	550	-	256,960	1,731,678
	占比	37.69%	11.43%	1.18%	34.41%	0.26%	0.16%	0.03%	0.00%	14.84%	100.00%
體育館	能耗	992,877	315,021	15,155	47,813	-	52,224	180,000	-	127,197	1,730,286

各樓館九大能源佔比

館別		空調系統	照明系統	冷凍冷藏系統	事務設備系統	送排風系統	給水污水系統	電梯系統	熱能用量的相當電力用量(kWh/Y)	其他	該空間總耗能(kWh/Y) 合計相當電力
短月別	占比	57.38%	18.21%	0.88%	2.76%	0.00%	3.02%	10.40%	0.00%	7.35%	100.00%
圖書館	能耗	4,868,849	445,437	23,123	128,631	227	32,646	225,000	-	385,043	6,108,956
	占比	79.70%	7.29%	0.38%	2.11%	0.00%	0.53%	3.68%	0.00%	6.30%	100.00%
活動中心	能耗	277,560	33,659	21,024	21,207	-	21,783	-	-	15,441	390,675
	占比	71.05%	8.62%	5.38%	5.43%	0.00%	5.58%	0.00%	0.00%	3.95%	100.00%
守謙	能耗	333,435	10,717	1,139	14,974	-	-	115,200	-	15,082	490,546
	占比	67.97%	2.18%	0.23%	3.05%	0.00%	0.00%	23.48%	0.00%	3.07%	100.00%
視聽教育館	能耗	25,645	5,981	-	47,541	-	-	-	-	2,567	81,734
	占比	31.38%	7.32%	0.00%	58.17%	0.00%	0.00%	0.00%	0.00%	3.14%	100.00%
其他	能耗	71,987	118,429	112,916	149,130	131,859	71,605	-	18,321	61,944	736,191
	占比	9.78%	16.09%	15.34%	20.26%	17.91%	9.73%	0.00%	2.49%	8.41%	100.00%
麗澤學舍	能耗	104,990	25,281	4,493	5,095	38	4,995	-	-	88,897	233,787
	占比	44.91%	10.81%	1.92%	2.18%	0.02%	2.14%	0.00%	0.00%	38.02%	100.00%
教育館	能耗	110,821	57,554	8,128	48,989	-	9,794	60,000	-	30,121	325,407
	占比	34.06%	17.69%	2.50%	15.05%	0.00%	3.01%	18.44%	0.00%	9.26%	100.00%
外語大樓	能耗	106,824	108,819	5,267	51,388	-	16,731	60,000	-	28,899	377,927
	占比	28.27%	28.79%	1.39%	13.60%	0.00%	4.43%	15.88%	0.00%	7.65%	100.00%
建築館	能耗	176,342	52,450	2,562	32,126	53,076	-	-	-	39,155	355,712
	占比	49.57%	14.75%	0.72%	9.03%	14.92%	0.00%	0.00%	0.00%	11.01%	100.00%
司令台	能耗	46,488	6,600	3,373	21,025	-	2,701	-	-	12,484	92,670
	占比	50.17%	7.12%	3.64%	22.69%	0.00%	2.91%	0.00%	0.00%	13.47%	100.00%
風工程	能耗	46,365	13,219	2,023	82,588	3,944	21,783	-	-	603,498	773,420
	占比	5.99%	1.71%	0.26%	10.68%	0.51%	2.82%	0.00%	0.00%	78.03%	100.00%
全校	能耗	15676187.81	3199670.948	957785.4577	4236300.491	1420947.43	601753.6586	1065750	176119.0919	7901748.305	35236263.19
	占比	44.49%	9.08%	2.72%	12.02%	4.03%	1.71%	3.02%	0.50%	22.43%	100.00%

館別		空調系統	照明系統	冷凍冷藏系統	事務設備系統	送排風系統	給水污水系統	電梯系統	熱能用量的相當電力用量 (kWh/Y)	其他	該空間總耗能 (kWh/Y) 合計相當電力
台北校園	能耗	487968.587	103704.164	13753.8	226326.7816	3613.76	46567.9	31901.1	31432.2903	49019.817	994288.1828
	占比	49.08%	10.43%	1.38%	22.76%	0.36%	4.68%	3.21%	3.16%	4.93%	100.00%

館別		空調系統	照明系統	冷凍冷藏系統	事務設備系統	送排風系統	給水污水系統	電梯系統	熱能用量的相當電力用量 (kWh/Y)	其他	該空間總耗能 (kWh/Y) 合計相當電力
CL	能耗	358034.55	142260.81	3600	116846.9	2950.3	0	104220	0	27274.37	755186.93
	占比	47.41%	18.84%	0.48%	15.47%	0.39%	0.00%	13.80%	0.00%	3.61%	100.00%
SA	能耗	560	64236.36	0	16204.75	73	0	15336	0	161.6	96571.71
	占比	0.58%	66.52%	0.00%	16.78%	0.08%	0.00%	15.88%	0.00%	0.17%	100.00%
FR	能耗	46212	14131.456	7006	14124	0	0	23760	0	10141.4	115374.856
	占比	40.05%	12.25%	6.07%	12.24%	0.00%	0.00%	20.59%	0.00%	8.79%	100.00%
JF	能耗	1955.2	161864.44	22350	29242.25	0	0	47520	0	98112	361043.886
	占比	0.54%	44.83%	6.19%	8.10%	0.00%	0.00%	13.16%	0.00%	27.17%	100.00%
WF	能耗	3769.6	2764.8	4672	26127.4	1610.4	0	47520	0	369	86833.2
	占比	4.34%	3.18%	5.38%	30.09%	1.85%	0.00%	54.73%	0.00%	0.42%	100.00%
P	能耗	2280	146	876	21024	0	0	0	0	0	24326
	占比	9.37%	0.60%	3.60%	86.43%	0.00%	0.00%	0.00%	0.00%	0.00%	100.00%
其他	能耗	68356.6	229793.78	0	0	164743	0	0	1151987	0	1614880.38
	占比	4.23%	14.23%	0.00%	0.00%	10.20%	0.00%	0.00%	71.34%	0.00%	100.00%
蘭陽校園 整體	能耗	481167.95	615197.64	38504	223569.3	169376.7	0	238356	1151987	136058.37	3054216.962
	占比	15.75%	20.14%	1.26%	7.32%	5.55%	0.00%	7.80%	37.72%	4.45%	100.00%